

+ FIRST AID

UPDATE

February 22, 2010

U.S.A. and Canada: dial 1 800 465-7325

Others: dial (514) 523-8324 (Canada)

Product and company identification:

Product name: Water-Repellent for Retaining Walls
Material uses: Water repellent for concrete and masonry.
Supplier/Manufacturer: Techniseal
300, avenue Liberte
Candiac, QC, Canada, J5R 6X1
Tel: (514) 523-2110
Toll free: 1-800-465-7325
Fax: (450) 633-3035

In case of emergency: CANUTEC (613) 996-6666

First aid measures:

Eye contact: Check for and remove any contact lenses. Immediately flush eyes with plenty of water for at least 15 minutes, occasionally lifting the upper and lower eyelids. Get medical attention if symptoms occur.

Skin contact: In case of contact, immediately flush skin with plenty of water for at least 15 minutes while removing contaminated clothing and shoes. Wash clothing before reuse. Clean shoes thoroughly before reuse. Get medical attention if symptoms occur.

Inhalation: Move exposed person to fresh air. If not breathing, if breathing is irregular or if respiratory arrest occurs, provide artificial respiration or oxygen by trained personnel. Loosen tight clothing such as a collar, tie, belt or waistband. Get medical attention if symptoms occur.

Ingestion: Wash out mouth with water. Do not induce vomiting unless directed to do so by medical personnel. Never give anything by mouth to an unconscious person. Get medical attention if symptoms occur.

Protection of first-aiders: No action shall be taken involving any personal risk or without suitable training.

Notes to physician: No specific treatment. Treat symptomatically. Contact poison treatment specialist immediately if large quantities have been ingested or inhaled.

Fire-fighting measures:

Flammability of the product: In a fire or if heated, a pressure increase will occur and the container may burst.

Extinguishing media:

Suitable: Use an extinguishing agent suitable for the surrounding fire.

Not suitable: None known

Special exposure hazards: Promptly isolate the scene by removing all persons from the vicinity of the incident if there is a fire. No action shall be taken involving any personal risk or without suitable training.

Hazardous thermal decomposition products: Decomposition products may include the following materials: carbon dioxide, carbon monoxide and metal oxide/oxides.

Special protective equipment for fire-fighters: Fire-fighters should wear appropriate protective equipment and self-contained breathing apparatus (SCBA) with a full face-piece operated in positive pressure mode.

Disposal considerations:

Waste disposal : The generation of waste should be avoided or minimized wherever possible. Empty containers or liners may retain some product residues. This material and its container must be disposed of in a safe way. Dispose of surplus and non-recyclable products via a licensed waste disposal contractor. Disposal of this product, solutions and any by-products should at all times comply with the requirements of environmental protection and waste disposal legislation and any regional local authority requirements. Avoid dispersal of spilled material and runoff and contact with soil, waterways, drains and sewers.

Disposal should be in accordance with applicable regional, national and local laws and regulations.

Other information:

Label requirements : NOT EXPECTED TO PRODUCE SIGNIFICANT ADVERSE HEALTH EFFECTS WHEN THE RECOMMENDED INSTRUCTIONS FOR USE ARE FOLLOWED.

Hazardous Material Information System (U.S.A.) :

Health	0
Flammability	0
Physical hazards	0

Caution: HMIS® ratings are based on a 0-4 rating scale, with 0 representing minimal hazards or risks, and 4 representing significant hazards or risks. Although HMIS® ratings are not required on MSDSs under 29 CFR 1910.1200, the preparer may choose to provide them. HMIS® ratings are to be used with a fully implemented HMIS® program. HMIS® is a registered mark of the National Paint & Coatings Association (NPCA). HMIS® materials may be purchased exclusively from J. J. Keller (800) 327-6868.

The customer is responsible for determining the PPE code for this material.

National Fire Protection Association (U.S.A.) :



Date of issue : 9/3/2009.
Date of previous issue : No previous validation
Version : 1